Revisions for two editions of the *PE Electrical and Computer: Power Practice Exam* are included in this document.
Make sure the ISBN at the top of the page matches the ISBN on the back cover of your book.

**ERRATA for**
***PE Electrical and Computer: Power Practice Exam***
**ISBN 978-1-947801-16-5**
Copyright © 2020 1st printing August 2020
Errata posted 09-15-2020

**Revisions are shown in red.**

**Question 12, p. 12:**
The question should read as follows:

**12.** When using the method of symmetrical components, which of the following statements are most nearly correct?

Select **all** that apply.

- ☐ A. The three positive-sequence voltage phasors are equal in magnitude and displaced by 120°.
- ☐ B. The three negative-sequence voltage phasors are equal in magnitude and displaced by 120°.
- ☐ C. The three zero-sequence voltage phasors are equal in magnitude and displaced by 120°.
- ☐ D. The set of positive-sequence voltage phasors and set of negative-sequence voltage phasors have opposite phase rotation.
- ☐ E. The magnitude of the Phase A positive-sequence voltage phasor is equal to the magnitude of the Phase A negative-sequence voltage phasor.

**Question 78, p. 45:**
The figure should be shown as follows:



Revisions for two editions of the *PE Electrical and Computer: Power Practice Exam* are included in this document.
Make sure the ISBN above matches the ISBN on the back cover of your book.

**ERRATA for**
***PE Electrical and Computer: Power Practice Exam***
**ISBN 978-1-932613-92-6**
Copyright 2017
Errata posted 6-27-2019

**Revisions are shown in red.**

**Question 129, p. 21:**

The third sentence of Question 129 should read as follows:

Feeder F1 consists of three 500-kcmil THWN-2 copper phase conductors and a neutral in a steel conduit that runs a distance of 250 feet.

**Question 526, p. 45:**

Question 526 should read as follows:

Each time a piece of equipment fails, it takes 12 hours to repair and return it to service. In order to have the equipment available at least 99.5% of the time, the maximum mean time to failures (MTTF) of the equipment (hours) is most nearly:

(A) 2,388
(B) 4,000
(C) 4,391
(D) 8,748