

ERRATA for
PE Civil: Water Resources and Environmental Practice Exam
ISBN: 978-1-947801-33-2
Copyright 2023
Errata posted 10/01/2024

Revisions are shown in red.

Question 12, p. 9:

Select the **two** that apply.

Question 21, p. 13:


A western community uses a water treatment facility to treat raw well water for iron and manganese removal. The water plant is no longer allowed to direct discharge backwash waste to the local receiving stream. The facility has **four, 12-ft square** gravity filters. A new red water lagoon is proposed to contain all backwash waste. Assume the average backwash rate is 15 gpm/ft² and the facility backwashes each filter in a single day once per week for 25 min. each. According to TSS Water Works 2018, the minimum lagoon size (ft) required is most nearly:

Question 28, p. 16:

A water system is replacing a 5,000-ft section of 48-in. cast iron discharge pipe from a **25-MGD** water treatment plant **with** C900 plastic. If the Hazen-Williams head loss coefficient for the cast iron is 100 while the C900 coefficient is 130, the **minimum new** line size (in.) **that would not result in added head loss is most nearly:**

Question 33, p. 19:

The channel shown has a longitudinal slope of 0.001 ft/ft **and a 100-ft-wide** overbank section necessary to keep the water depth in the channel no greater than 10 ft under uniform velocity. **The maximum design flood (cfs) that this channel can support is most nearly:**




- A. 2,512.9
- B. 2,380.5
- C. 2,240.1
- D. 1,932.9


ERRATA for
PE Civil: Water Resources and Environmental Practice Exam
ISBN: 978-1-947801-33-2
Copyright 2023
Errata posted 10/01/2024

Question 54, p. 33:
Select the **four** that apply.

Question 56, p. 34:



WATER TREATMENT SITE PLAN



HYDROGEOLOGIC CROSS-SECTION OF WELL FIELD

ERRATA for
PE Civil: Water Resources and Environmental Practice Exam

ISBN: 978-1-947801-33-2

Copyright 2023

Errata posted 10/01/2024

Question 66, p. 39:

The primary clarifier of a trickling filter plant receives 1,000 lb of solids daily. The clarifier has a solids capture rate of 90% and produces an underflow sludge concentration of 9% (**SG = 1.05**). The volume of primary sludge (ft³/day) is most nearly:

- A. 2
- B. 80
- C. **150**
- D. 210

Question 70, p. 41:

- C. **867.51**

Solution 12, p. 52:

The following options are correct.

Option B: Polyvinyl chloride pipe (PVC) is commonly used for small sewers.

Option D: Vitrified clay pipe (VCP) is old technology but could be used.

THE CORRECT ANSWERS ARE: B, D

Solution 18, p. 55:

B. $120 \text{ ft} \times 115 \text{ ft} \times 12 \text{ ft} = 165,600 \text{ ft}^3$ — too small

ERRATA for
PE Civil: Water Resources and Environmental Practice Exam
ISBN: 978-1-947801-33-2
Copyright 2023
Errata posted 10/01/2024

Solution 28, p. 61:

Use the Hazen-Williams equation for head loss.

$$Q = 25,000,000 \text{ gal/day} \rightarrow \frac{25,000,000}{7.48 \text{ g/ft}^3} \left(\frac{1}{24 \text{ hr/day} \times 60 \times 60} \right) = 38.68 \text{ cfs}$$

$$L = 5,000 \text{ ft}$$

$$C = 100$$

$$D = 48 \text{ in./12} = 4 \text{ ft}$$

$$\text{Existing } h_f = \frac{4.73(5,000)}{100^{1.852} 4^{4.87}} (38.68)^{1.852} = 4.762 \text{ ft}$$

$$\frac{4.73(5,000)(38.68)^{1.852}}{130^{1.852} 4^{4.87}} = 2.92 \text{ ft}$$

48-in. pipe is the smallest size that doesn't increase head loss.

Solution 33, p. 62:

$$n_1 = 0.14$$

$$S_1 = 0.001 \text{ ft/ft}$$

$$A_1 = 6 \times 100 \text{ ft}^2 = 600 \text{ ft}^2$$

$$P_{w1} = 6 + 100 = 106 \text{ ft}$$

$$R_{H1} = \frac{A_1}{P_{w1}} = \frac{600}{106} \text{ ft} = 5.66 \text{ ft}$$

$$Q_1 = \frac{1.49}{n_1} A_1 (R_{H1})^{2/3} (S_1)^{1/2} = \frac{1.49}{0.14} \times 600 (5.66)^{2/3} \times (0.001)^{1/2}$$
$$= 645 \text{ ft}^3/\text{sec}$$

$$n_2 = 0.05$$

$$S_2 = 0.001$$

$$A_2 = 50 \times 10 \text{ ft}^2 = 500 \text{ ft}^2$$

$$P_{w2} = 4 + 50 + 10 = 64 \text{ ft}$$

$$R_{H2} = \frac{A_2}{P_{w2}} = \frac{500}{64} \text{ ft} = 7.81 \text{ ft}$$

$$Q_2 = \frac{1.49}{n_2} A_2 (R_{H2})^{2/3} (S_2)^{1/2} = \frac{1.49}{0.05} \times 500 (7.81)^{2/3} \times (0.001)^{1/2}$$
$$= 1,867.9 \text{ ft}^3/\text{sec}$$

$$Q = Q_1 + Q_2 = (645 + 1,867.9) \text{ cfs}$$
$$= 2,512.9 \text{ cfs}$$

THE CORRECT ANSWER IS: A

ERRATA for
PE Civil: Water Resources and Environmental Practice Exam

ISBN: 978-1-947801-33-2

Copyright 2023

Errata posted 10/01/2024

Solution 49, p. 68:

Specific capacity = Q/D_w

Solution 54, p. 71:

Option A: In a water/wastewater environment, red, green, and brown algae all contain chlorophyll.

THE CORRECT ANSWERS ARE: A, B, C, E

Solution 66, p. 75:

Refer to the Sludge Production section in the *PE Civil Reference Handbook*.

Using equation $V_S = \frac{M}{P_S S_S g_w}$

Use SG of sludge = 1.05

$M = 1,000 \text{ lb/day} (0.9) = 900 \text{ lb/day}$

$P_S = 0.09$

$S_S = 1.05$

$g_w = 62.4 \text{ lb/ft}^3$

$V_S = \frac{900 \text{ lb/day}}{(0.09)(1.05)(62.4 \text{ lb/ft}^3)} = 152.6 \text{ lb/ft}^3$

$V_S = 153 \text{ lb/ft}^3$

Round to tens digits = 150 lb/ft^3

Solution 70, p. 77:

$v^2 = 1.056 \text{ (ft/sec)}^2 \rightarrow v = 1.028 \text{ ft/sec}$

$Q = VA$

$A = 5.41/1.028 = 5.26 \text{ ft}^2/2.5 \text{ ft wide} = 2.11 \text{ ft deep}$

Wet well elevation minimum = $2.11 \text{ ft} + 865.40 = 867.51 \text{ ft}$